



CITY OF MISSION

"Home of the Grapefruit"

December 1, 2016

RE: **Addendum No. 4/City of Mission Event Center**
Request for Proposal No.: 17-010-11-29

Dear Prospective Offeror:

The following is to be corrected/added/changed/clarified: This addendum is being issued in response to the following questions:

- a. **Clarification:** Please refer to the attached clarifications and revisions to specifications and plans, prepared by the design team.
- b. The proposal due date has not changed. The date for receipt of proposals is **Friday, December 2, 2016 at 2:00 p.m. CST**
- c. No other changes result from this Addendum No. 4.

NOTE: This form must be completed and submitted with your bid response. WARNING: Failure of an Offeror to acknowledge receipt of this Addendum, as described herein, may result in REJECTION OF THE OFFER.

We apologize for any inconvenience this may have caused. Authorized signature is needed. Everything else shall remain the same. If you have any questions, please contact me at (956) 580-8667.

Sincerely,


Eduardo Belmarez
Purchasing Director

Authorized Signature Acknowledge receipt of Addendum No. 4

Printed Name

Company Name



ADDENDUM 4

.....
Date: 11-30-2016

Project: Mission Event Center

Project No.: 2016-01
.....

The following Addendum shall supersede and modify the original plans and specifications and shall be part of the Contract Documents.

GENERAL:

1. *Clarification:* **Section 27 10 00 Part 2, paragraph 2.4.** All cabling shall be CAT6 (equal to 4763214/10 by Commscope) and all jack inserts (equal to 2-1375055-6 by Commscope)/ patch panels (equal to UNP610-48P by Commscope) for structured cable systems.

STRUCTURAL

2. *Question:* The structural fill for the building pad construction is to be either Flex Base Item 247 Type E, Grade 4- Caliche or Flex Base Item 247 Type A, Grade 1- Limestone.
Answer: Correct