



CITY OF MISSION

"Home of the Grapefruit"

January 22, 2018

RE: **Addendum No. 2/Fencing Project for New Dog Parks at Bannworth and Bentsen Palm Community Parks RFB: 18-113-01-22**

Dear Prospective Bidder:

The following is to be corrected/added/changed/clarified:

- a. This addendum is being provided to all bidders. Changes are marked with a vertical line on the right hand side.
- b. Question: Can you provide the missing dimensions for both parks?
Answer:
Bannworth Park:
 - Exterior Fence to include measurement of required fencing at main entrance / gated safety entrances and circular training areas:
 - 1,504.97 linear feet
 - Inner fenced walkway and oval area in middle of park and extension to connect to east fence line:
 - 478.5 linear feet
- **Bentsen Palm Community Park:**
 - Exterior Fence to include measurement of required fencing at main entrance / gated safety entrances:
 - 1,257.78 linear feet
 - Interior fenced walkway and oval area in middle of park and extension to connect to south fence line:
 - 606.65 linear feet
- c. Question: Regarding the bottom tension wire, how is this to be fastened? Crimped?
Answer: **Change from 7 gauge to 9 gauge galvanized tension wire fashioned to chain link fabric with 11 gauge hog rings @ 24" centers.**
- d. Question: What color for the fence?
Answer: **To be standard silver galvanized. NOT to be color vinyl coated.**
- e. Question: Can the cement be hand mixed?
Answer: **Hand mixing preferred due to existing irrigation system.**
- f. Question: What is the estimated budget for this project?
Answer: **There is no estimated budget at this time.**
- g. The bid due date has not changed. The date for receipt of bids is **Thursday, February 1st, 2018 at 2:00 P.M. CST.**

g. The bid due date has not changed. The date for receipt of bids is Thursday, February 1st, 2018 at 2:00 P.M. CST.

NOTE: This form must be completed and submitted with your bid response. WARNING: Failure of an Offeror to acknowledge receipt of this Addendum, as described herein, may result in REJECTION OF THE OFFER.

We apologize for any inconvenience this may have caused. Authorized signature is needed. Everything else shall remain the same. If you have any questions, please contact me at (956) 580-8667.

Sincerely,



Eduardo Belmarez
Purchasing Director

_____ Acknowledge receipt of Addendum No. 2
Authorized Signature

Printed Name

Company Name