

CITY OF MISSION

"Home of the Grapefruit"

April 18, 2018

RE: Addendum No. 1/ RFB: 18-183-04-23 Replacement of a 10-inch High Service Pump and Motor at North Water Treatment Plant

Dear Prospective Bidder:


The following is to be corrected/added/changed/clarified:

- a. This addendum is being provided to all bidders. Changes are marked with a vertical line on the right hand side.
- b. Question: Will an allowance be included?
Answer: Yes, \$5,000 (See attached pricing schedule)
- c. Changed: See revised attached pricing schedule.
- d. Correction: Peerless Pump model number, 10AE14A.
- e. Question: Will you accept equivalent pumps?
Answer: Yes.
- f. Question: What is the warranty requirement?
Answer: Two year parts and labor on Peerless Pump and any equivalent pump offered in the submittal.
- g. Added: Certificate required.
ANSI/NSF Standard 61
All newly installed pipes and related products must conform to American National Standard Institute/NSF International (ANSI/NSF) Standard 61 and must be certified by an organization accredited by ANSI. The contractor must submit certification demonstrating that the pump meets requirements.
- h. We are not entertaining any other questions at this time.
- i. The bid due date has not changed. The date for receipt of bids is **Thursday, April 23rd, 2018 at 2:00 P.M. CST.**

NOTE: This form must be completed and submitted with your bid response. WARNING: Failure of an Offeror to acknowledge receipt of this Addendum, as described herein, may result in REJECTION OF THE OFFER.

We apologize for any inconvenience this may have caused. Authorized signature is needed. Everything else shall remain the same. If you have any questions, please contact me at (956) 580-8667.

Sincerely,



Eduardo Belmarez,
Purchasing Director

_____ Acknowledge receipt of Addendum No. 1
Authorized Signature

Printed Name

Company Name

