



# CITY OF MISSION

*"Home of the Grapefruit"*

September 12, 2018

RE: **Addendum No. 1/ RFB: 18-282-09-13 Storm Drainage Materials**

Dear Prospective Bidder:

The following is to be corrected/added/changed/clarified:

- a. This addendum is being provided to all bidders.
- b. Question: Items No. 1-4 are they required to be tongue and groove? Or do you prefer rubber gasket, which is the most common pipe here in the valley?

**Answer: Rubber gasket is preferred.**

- c. Question: Item No. 7 is it supposed to be Type "M" Manhole? Is type MM a typo?

**Answer: Correction, should read type "M".**

- d. We are not entertaining any other questions at this time.

- e. The bid due date has changed. **The date for receipt of bid is Friday, September 14<sup>th</sup>, 2018 at 2:00 P.M. CST.**

**NOTE: This form must be completed and submitted with your bid response. WARNING: Failure of an Offeror to acknowledge receipt of this Addendum, as described herein, may result in REJECTION OF THE OFFER.**

We apologize for any inconvenience this may have caused. Authorized signature is needed. Everything else shall remain the same. If you have any questions, please email Purchasing Buyer, Crissy Cantu, at [ccantu@missiontexas.us](mailto:ccantu@missiontexas.us).

Sincerely,

Eduardo Belmarez,  
Purchasing Director

\_\_\_\_\_ Acknowledge receipt of Addendum No. 1

Authorized Signature

\_\_\_\_\_  
Printed Name

\_\_\_\_\_  
Company Name

1201 E. 8th St. • Mission, Texas 78572 • [www.missiontexas.us](http://www.missiontexas.us)